

ETV Bronze Valve Actuator Wiring Addendum

This addendum is to wire the ETV Bronze Valve Actuator to an ETV control. An Upgrade kit (Part #950023-00) must be used. In addition, no wiring should be applied to the ETV control terminals 3 and 4. Kit includes an External Transformer to wire the Bronze Valve Actuator. Transformer Enclosure must be Earth Grounded for safety.

WARNING

- Do not wire the ETV Control Terminals 3 & 4 when using the external transformer.
- Transformer is part of an upgrade kit and must be purchased through Heat-Timer Corp. (Upgrade Kit Part Number #950023-00)
- Must ground Transformer Electrical box to EARTH GROUND.

